



PSF3

King County Fire Marshal's Office
Department of Development and Environmental Services
900 Oaksdale Avenue Southwest Renton, WA 98055-1219 (206) 296-6675

Permit No. F96-0075

Date Expires: 09/05/2002

BOEING COMMERCIAL AIRPLANE CO. BLDG 3-800
POST OFFICE BOX 3707 M/S:19-35
SEATTLE, WA 98124-2207

Business Name: BOEING BLD 3-800
Site Address: 7277 PERIMETER RD S KC
Fire District: KCA
Location:

THIS PERMIT IS GRANTED FOR:

Cond: CON1095547

PLACE OF ASSEMBLY UFC 25.101 POSTING OF ROOM CAPACITY. Any room having an occupant load

of 50 or more where fixed seats are not installed, and which is used for classroom, assembly or similar purpose, shall have the capacity of the room posted in a conspicuous place on an approved sign near the main exit from the room. Such sign shall be maintained legible by the owner or his authorized agent and shall indicate the number of occupants permitted for each room use. THE FOLLOWING ROOM(S) MUST BE POSTED:

Cond: CON1095548

ROOM #137 = 96 TELECONFERENCE ROOM #1 = 56 ROOM #145 = 180

TELECONFERENCE ROOM #2 = 56

ROOM #146 = 76 ROOM #150 = 79

Cond: CON1095549

Flammable/Combustible Liquids Storage, Use or Handling as Defined in Uniform Fire Code 4.108,f3 CLASS II OR III-A LIQUIDS

NOTICE

1. This permit does not take the place of any License required by law and is NOT TRANSFERABLE. Any change in use, occupancy, or ownership of the premises shall require a new permit.
2. THIS PERMIT AND ANY ATTACHED CONDITIONS MUST BE POSTED IN A CONSPICUOUS PLACE ON THE PREMISES.
3. This permit is subject to the satisfactory completion of all corrections identified in the original or renewal inspection and all conditions that are attached.
4. This permit EXPIRES (09/05/2002)
5. Call 296-6675 for inspection requests and information regarding this permit.